



NOTE:  
 THE RECOMMENDED PIPE FOR USE IN SUSPENDING BELOW GRADE APPLICATIONS IS EXTRA HEAVY CAST IRON SOIL PIPE BEARING THE TRADEMARK OF THE CAST IRON SOIL PIPE INSTITUTE (CISPI), AND BE LISTED BY NSF INTERNATIONAL.

MINIMUM PIPE SLOPE PER IPC	
2 1/2" OR LESS	1/4"
3" - 6"	1/8"
8" OR LARGER	1/16"

**NOTICE:** THE INFORMATION ON THIS PAGE PROVIDES GENERAL GUIDELINES. IT SHOULD BE USED ONLY AS A REFERENCE AND NOT AS A GAURANTEE OF PERFORMANCE. SPECIFIC INSTALLATION INSTRUCTIONS AND TECHNIQUES MAY BE REQUIRED AS A RESULT OF LOCAL PLUMBING AND BUILDING CODES, ENGINEERING SPECIFICATIONS AND INSTRUCTIONS.

## UNDERGROUND PIPE SUSPENDED FROM SLAB DETAIL A2

